## 7.1.2 Federal Minimum Efficiency Standard for Commercial Cooling Equipment from the Energy Policy Act of 2005 (1) 65 - 134 kBtu/h 135 - 239 kBtu/h 240 - 759 kBtu/h **Type** Central Air Conditioner (EER) without heating or electrical resistance heating 11.2 11.0 10.0 without heating equipment 11.0 10.8 9.8 Central Air Heat Pump (EER) -- Cooling 10.6 without heating or electrical resistance heating 11.0 9.5 without heating equipment 10.8 10.4 9.3 Central Air Heat Pump (COP) -- Heating 3.3 3.2 3.2 Note(s): 1) The effective date of these manufacturing standards is January 1, 2010. Source(s): U. S. Government, Energy Policy Act of 2005, August 2005, Section 136, Paragraphs 7-9.